



中国国家强制性产品认证证书

证书编号: 2016010301889135

委托人名称、地址

上海天逸电器有限公司

上海市松江区车墩镇北闵路 101 号第二、三幢

生产者(制造商)名称、地址

上海天逸电器有限公司

上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称、地址

上海天逸电器有限公司

上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

低压成套开关设备

TYZC 主母线: InA=400A~10A, Icw=10kA; Ue=400V/230V, Ui=690V; 50Hz; IP65

产品标准和技术要求

GB/T7251.12-2013

上述产品符合强制性产品认证实施规则 CNCA-C03-01:2014 的要求,
特发此证。

发证日期: 2017 年 07 月 03 日 有效期至: 2021 年 08 月 03 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016 年 08 月 03 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主 任:



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010301889135

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3,No.101,Beimin Road,Chedun Town,Songjiang District, Shanghai

PRODUCT NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies
TYZC 主母线:InA=400A~10A,Icw=10kA;Ue=400V/230V,Ui=690V;50Hz;IP65

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T7251.12-2013

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-01:2014).

Valid from: Jul.03,2017

Valid until: Aug.03,2021

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.03,2016

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE