



# 产品认证证书

证书编号: CQC20012248421

申请人名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

上海天逸电器有限公司 (V005556)  
上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

按钮开关

LA42(V)S..., TPB1S...; Ui:690V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:  
380V/4A, 240V/6A, 24V/6A; A600(380V/1.9A, 240V/3A, 120V/6A); DC-13:Ue/Ie: 220V/0.5A, 110V/1.2A, 48V/3A, 24V/6A;  
N600(125V/2.2A, 250V/1.1A); Q600(125V/0.55A, 250V/0.27A); IP65(头部); 安装孔径:Φ22; 灯片:Ui:690V; Ue:  
AC110V, 220V, 380V, 50Hz/60Hz, AC/DC6V, 12V, 24V, 36V, 48V, 110V, 220V, 50Hz/60Hz; 型号解释详见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 05 月 26 日 有效期至: 2025 年 05 月 26 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0270979



# 产品认证证书

附 录

证书编号: CQC20012248421

第 1 页 共 4 页

纸 号: 270979

型号的解释:

<u>  </u>	<u>  </u>	<u>  </u>	<u>  </u>	<u>  </u>	-	<u>  </u>	<u>  </u>	/	<u>  </u>	<u>  </u>	<u>  </u>
a	b	c	d	e		f	g		h	i	j

a: 型号代码

LA42(V)S : 一般型

TPBIS : 经济型

b: 钮头代号:

P: 平钮

PS: 自锁平钮

M: 蘑菇钮

MS: 自锁蘑菇头

H: 双位按钮

J: 紧停钮 J

JT: 推拉式紧停钮

X: 短柄旋钮

XL: 长柄旋钮

Y: 钥匙钮

Y30N: 电梯专用钥匙钮 (\*为钮头丝印标识符号: 用数字标识。如 LA42(V)SY30N3)

c: 带灯钮: D (产品上铭牌为 D-VII, VII 表示设计号) 无标记: 不带灯

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 产品认证证书

附录

证书编号: CQC20012248421

第 2 页 共 4 页

纸 号: 270979

d: 操作档位: 适用于 X、XL、Y、Y3ON 型

2: 两位 60°自锁

2A: 两位 45°自复位

29: 两位 90°自锁

2A9: 两位 90°自复

3: 三位 60°自锁

3A: 三位 45°自复

3AL: 三位左自复右自锁

3AR: 三位左自锁右自复

e: 钥匙可拨位置, 适用于 Y、Y3ON 型

无标记: 仅在初始位置可拨

B: 所有位置可拨

C: 初始和左侧位置可拨, 右侧不可拨

D: 初始和右侧位置可拨, 左侧不可拨

f: 触点模块型式: 无标记: 常规触点模块、H: 大容量型触点模块、L: 高可靠性触点模块 K: 快动触点模块

g: 触点构成: 10、01、20、11、02、30、21、12、03、40、31、22、13、04、50、41、32、23、14、05、60、51、42、33、24、15、06。第一位数字表示常开触点数量, 第二位数字表示常闭触点数量, 如 32 表示 3 常开 2 常闭

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附 录

证书编号: CQC20012248421

第 3 页 共 4 页

纸 号: 270979

h: 电压: 带灯片电压 (不带灯产品无此项) 具体见下表 1;

表 1

带灯片电压 (LED 灯)
AC380V、220V、110V(50Hz/60Hz)
AC/DC220V、110V、48V、36V、24V、12V、6V( 50Hz/60Hz )

i: 颜色代码: R (红), G (绿), Y (黄), W (白), S (蓝), B (黑), A (灰)

j: 客户编号 (编号与产品结构无关):

000~099: .....

100~199: 奥的斯电梯

200~299: 三菱电梯

xxx~xxx: .....

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# 产品认证证书

附 录

第 4 页 共 4 页

证书编号: CQC20012248421

纸 号: 270979

按钮附件标准产品:  $\frac{\square}{1} \frac{\square}{2} - \frac{\square\square}{3} \frac{\square\square}{4}$

1 触点模块基本型号:

VB: 一般型触点模块

TB: 经济型触点模块

2 触点模块型式:

S: 常规触点模块、H: 大容量型触点模块、L: 高可靠性触点模块、K: 快动触点模块

3 模块构成:

10、01、20、11、02、30、21、12、03、40、31、22、13、04、50、41、32、23、14、05、60、  
51、42、33、24、15、06

第一位数字表示常开触点数量, 第二位数字表示常闭触点数量, 如 32 表示 3 常开 2 常闭

4-客户编号(编号与产品结构无关):

000~099: .....

100~199: 奥的斯电梯

200~299: 三菱电梯

xxx~xxx: .....

其他附件:

D-VII: 带灯片

PT-ZJ: 连接支架

PT-V: 套筒扳手(用于紧固按钮头部)

.....

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅

## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20012248421

## NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.  
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.  
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)  
Building 2,3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Button switch

LA42(V)S...,TPB1S...; Ui:690V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:  
380V/4A,240V/6A,24V/6A;A600(380V/1.9A,240V/3A,120V/6A); DC-13:Ue/Ie: 220V/0.5A,110V/1.2A,48V/3A,24V/6A;  
N600(125V/2.2A,250V/1.1A);Q600(125V/0.55A,250V/0.27A); IP65(head); Aperture :Φ22; Lampshade: Ui:690V; Ue:  
AC110V,220V,380V,50Hz/60Hz,AC/DC6V,12V,24V,36V,48V,110V,220V,50Hz/60Hz; See the Appendix for type explanation

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

## TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: May.26,2020

Valid until: May.26,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0270979