



产品认证证书

证书编号: CQC2009010304368746

申请人名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

上海天逸电器有限公司 (V005556)
上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

指示灯

AD17-60MC: Ui:400V; Uimp:0.5kV; Ue: AC400V、DC110V; 头部 IP65; 安装孔径: Φ 60mm

产品标准和技术要求

GB/T14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 05 月 08 日 有效期至: 2024 年 04 月 04 日
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0260198



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2009010304368746

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)
Building 2&3, No.101, Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Indicate Light
AD17-60MC: Ui:400V; Uimp:0.5kV; Ue: AC400V、DC110V; Head IP65; Mounting aperture: Φ
60mm

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019 .

Valid from: May.08,2020

Valid until: Apr.04,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0260198