



产品认证证书

证书编号: CQC2006010302197756

申请人名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

上海天逸电器有限公司 (V005556)
上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

隔离开关

LW42: Uimp: 4kV; Ui: 400V; Ith: 25A, 32A; (Ith25A)AC-3: Ie/Ue: 15A/400V(380V) AC-21B: Ie/Ue: 25A/400V(380V)
AC-23B: Ie/Ue: 24A/400V(380V) (Ith32A)AC-3: Ie/Ue: 26A/400V(380V) AC-21B: Ie/Ue: 32A/400V(380V)
AC-23B: Ie/Ue: 30A/400V(380V) Icw: 400A/1s; Icm: 1.41kA; 防护等级: IP65(安装面板以上部分)

产品标准和技术要求

GB/T14048.3-2017

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462141-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 05 月 08 日 有效期至: 2024 年 06 月 17 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0260194



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2006010302197756

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)
Building 2&3, No.101, Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Switch-disconnector

LW42: Uimp: 4kV; Ui: 400V; Ith: 25A,32A; (Ith25A)AC-3:le/Ue:15A/400V(380V) AC-21B:le/Ue:25A/400V(380V)
AC-23B:le/Ue:24A/400V(380V) (Ith32A)AC-3:le/Ue:26A/400V(380V) AC-21B:le/Ue:32A/400V(380V)
AC-23B:le/Ue:30A/400V(380V) Icw: 400A/1s; Icm: 1.41kA; IP65(Install the upper part of the panel)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462141-2019 .

Valid from: May.08,2020

Valid until: Jun.17,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0260194