



产品认证证书

证书编号: CQC21002281135

发证日期: 2021年01月11日

有效期至: 长期有效

委托人名称 上海天逸电器有限公司
及注册地址 上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称 上海天逸电器有限公司
及注册地址 上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称 欣大电气有限公司
及生产地址 浙江省乐清市乐清经济开发区纬十八路 319 号

产品名称和系列、规格、型号 继电器
TRS□□□□-□系列: 触点负载: 1Z:NO:15 /12A 277 /250VAC, 15 /12A 30VDC,1/2HP 250VAC;
NC:12A 277 /250VAC, 12A 30VDC, 1/2HP 250VAC; 2Z:NO:8A 277 /250VAC,8A 30VDC, 1/3HP
250VAC; NC:8A 250VAC, 8A 30VDC, 1/3HP 250VAC; 线圈电压: 5VDC,6VDC, 9VDC, 12VDC,
24VDC, 36VDC, 48VDC, 110VDC, 125VDC; 6VAC, 12VAC, 24VAC,36VAC, 48VAC, 110VAC,
125VAC, 220VAC, 230VAC, 240VAC; 线圈功率: 0.53W, 0.8VA;电气寿命: 100,000 周期; 机械寿
命: 10,000,000 周期; 环境温度: -40℃~85℃; RTIL(系列描述见附件)

产品标准和技术要求 GB/T 21711.1-2008

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462155-2010 认证规则的要求, 特发此证。

本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



签发: 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C 0459525



产品认证证书

附 录

证书编号: CQC21002281135

第 1 页 共 1 页

纸 号: 459525

型号命名规则:

T	R	S	□	□	□	□	□	-	□
1	2	3	4	5	6	7	8		9

1、T:企业标识

2、R: 电磁继电器

3、S: 设计序号 (薄型)

4、触头数量: 1: 1 组; 2: 2 组

5、T: 测试按钮; 无: 标准型

6、无: 标准型 (不带灯); L: 带灯; Y: 防浪涌; LY: 带灯+防浪涌

7、触头型式: 无: 转换; D/B: 常闭; H/A: 常开

8、触头负载 (可省略)

9、线圈电压: D5: 5VDC, D6: 6VDC, D9: 9VDC, D12: 12VDC, D36: 36VDC, D48: 48VDC, D110: 110VDC, D125: 125VDC; A6: 6VAC, A12: 12VAC, A24: 24VAC, A36: 36VAC, A48: 48VAC, A110: 110VAC, A125: 125VAC, A220: 220VAC, A230: 230VAC, A240: 240VAC; AC 为交流, DC 为直流

注: 此附录与证书同时使用时有效。



中国质量认证中心



PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC21002281135

Valid from: Jan.11,2021

Valid until:long-term

**NAME AND REGISTERED
ADDRESS OF THE APPLICANT**

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101, Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**NAME AND REGISTERED
ADDRESS OF THE
MANUFACTURER**

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101, Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**NAME AND LOCATION
OF THE FACTORY**

Clion ELECTRICAL CO.,LTD.
No.319 Wei 18th Road, Yueqing Economical Development Zone, Yueqing City, Zhejiang Province

**PRODUCT NAME, MODEL
AND SPECIFICATION**

RELAY
TRS□□□□-□系列: 触点负载: 1Z:NO:15 /12A 277 /250VAC, 15 /12A 30VDC,1/2HP 250VAC; NC:12A 277 /250VAC, 12A 30VDC, 1/2HP 250VAC; 2Z:NO:8A 277 /250VAC,8A 30VDC, 1/3HP 250VAC; NC:8A 250VAC, 8A 30VDC, 1/3HP 250VAC; 线圈电压: 5VDC,6VDC, 9VDC, 12VDC, 24VDC, 36VDC, 48VDC, 110VDC, 125VDC; 6VAC, 12VAC, 24VAC,36VAC, 48VAC, 110VAC, 125VAC, 220VAC, 230VAC, 240VAC; 线圈功率: 0.53W, 0.8VA;电气寿命: 100,000 周期; 机械寿命: 10,000,000 周期; 环境温度: -40°C~85°C; RTIL.(系列描述见附件)

**THE STANDARDS AND
TECHNICAL REQUIREMENTS
FOR THE PRODUCTS**

GB/T 21711.1-2008

**TYPE OF CERTIFICATION
SCHEMES**

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462155-2010.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

陆杨

CHINA QUALITY CERTIFICATION CENTRE

