



产品认证证书

证书编号：CQC20012248421

申请人名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路101号第二、三幢

制造商名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路101号第二、三幢

生产企业名称及地址

上海天逸电器有限公司(V005556)
上海市松江区车墩镇北闵路101号第二、三幢

产品名称和系列、规格、型号

按钮开关

LA42(V)S...,TPB1S...; Ui:690V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:
380V/4A,240V/6A,24V/6A;A600(380V/1.9A,240V/3A,120V/6A); DC-13:Ue/Ie: 220V/0.5A,110V/1.2A,48V/3A,24V/6A;
N600(125V/2.2A,250V/1.1A);Q600(125V/0.55A,250V/0.27A); IP65(头部); 安装孔径:Φ22; 灯片:Ui:690V; Ue:
AC110V,220V,380V,50Hz/60Hz,AC/DC6V,12V,24V,36V,48V,110V,220V,50Hz/60Hz; 型号解释详见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求，特发此证。

发证日期：2020年05月26日 有效期至：2025年05月26日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任： 陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0270979



产品认证证书

附 录

第 2 页 共 4 页

证书编号: CQC20012248421

纸 号: 270979

d: 操作档位: 适用于 X、XL、Y、Y3ON 型

2: 两位 60°自锁

2A: 两位 45°自复位

29: 两位 90°自锁

2A9: 两位 90°自复

3: 三位 60°自锁

3A: 三位 45°自复

3AL: 三位左自复右自锁

3AR: 三位左自锁右自复

e. 钥匙可拨位置, 适用于 Y、Y3ON 型

无标记: 仅在初始位置可拨

B: 所有位置可拨

C: 初始和左侧位置可拨, 右侧不可拨

D: 初始和右侧位置可拨, 左侧不可拨

f: 触点模块型式: 无标记: 常规触点模块、H: 大容量型触点模块、L: 高可靠性触点模块 K: 快动触点模块

g: 触点构成: 10、01、20、11、02、30、21、12、03、40、31、22、13、04、50、41、32、23、14、05、60、51、42、33、24、15、06。第一位数字表示常开触点数量, 第二位数字表示常闭触点数量, 如 32 表示 3 常开 2 常闭

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



产品认证证书

附 录

第 3 页 共 4 页

证书编号: CQC20012248421

纸 号: 270979

h: 电压: 带灯片电压 (不带灯产品无此项) 具体见下表 1;

表 1

带灯片电压 (LED 灯)
AC380V、220V、110V(50Hz/60Hz)
AC/DC220V、110V、48V、36V、24V、12V、6V(50Hz/60Hz)

i: 颜色代码: R (红), G (绿), Y (黄), W (白), S (蓝), B (黑), A (灰)

j: 客户编号 (编号与产品结构无关):

000~099:

100~199: 奥的斯电梯

200~299: 三菱电梯

xxx~xxx:

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20012248421

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)
Building 2,3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Button switch

LA42(V)S...,TPB1S...; Ui:690V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:
380V/4A,240V/6A,24V/6A;A600(380V/1.9A,240V/3A,120V/6A); DC-13:Ue/Ie: 220V/0.5A,110V/1.2A,48V/3A,24V/6A;
N600(125V/2.2A,250V/1.1A);Q600(125V/0.55A,250V/0.27A); IP65(head); Aperture :Φ22; Lampshade: Ui:690V; Ue:
AC110V,220V,380V,50Hz/60Hz,AC/DC6V,12V,24V,36V,48V,110V,220V,50Hz/60Hz; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection
This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019 .

Valid from: May.26,2020

Valid until: May.26,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0270979