



产品认证证书

证书编号: CQC2015010305806104

申请人名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

上海天逸电器有限公司 (V005556)
上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

限位开关

X42C; 型号解释详见附件;

Ui:690V; Uimp:6kV; Ith:10A; AC-15:Ue/Ie:120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/6A, 600V/1.2A; D
C-13:Ue/Ie:120V/0.55A, 250V/0.27A; IP65

产品标准和技术要求

GB/T 14048.5-2017

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 26 日 有效期至: 2025 年 08 月 26 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2020 年 05 月 08 日

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0376656



产品认证证书

附 录

第 1 页 共 1 页

证书编号: CQC2015010305806104

纸 号: 376656

型号的解释:

X42C- □□□/ □□-□-□-□-□□
a b c def g

a) 编号 X42C 系列

b) 触点类型 S11(速动一常开一常闭)、S20(速动二常闭)、S02(速动二常闭),

H11(缓动一常开一常闭)、H20(缓动二常开一常闭)、H02 缓动二常闭

c) 操动头编号 1Z (1 类柱型)、1ZTK (TK 类柱型)、2Z(2 类柱型)

1R(1 类直滚轮型)、1RTK (TK 类直滚轮型)、2R (2 类直滚轮型)

1K (1 类斜滚轮型)、2K (2 类斜滚轮型)、3K (3 类斜滚轮型)、4K (4 类斜滚轮型)

5K (5 类斜滚轮型)、1Y (1 类摆动型)、2Y (2 类摆动型)、3Y (3 类摆动型)

d) 操动头部方位: 空 (初始位)、1 (顺时针转 90 度)、2 (顺时针转 180 度)、3 (顺时针转 270 度)

e) 复位类型: 空 (自动复位)、S (手动复位)

f) 出现口位: 空 (两侧有出线孔)、1 (左侧有出线孔)、2 (右侧有出线孔)、3 (两侧没有出线孔)

g) 订货编号: 根据客户需要添加订货号

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2015010305806104

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)
Building 2,3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Limit switch
X42C;
Ui:690V;Uimp:6kV;lth:10A;AC-15:Ue/le:120V/6A,240V/3A,380V/1.9A,480V/1.5A,500V/6A,600V/1.2A;DC-13:Ue/le:120V/0.55A,250V/0.27A;IP65

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection
This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Aug.26,2020 **Valid until:** Aug.26,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: May.08,2020

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0376656