



# 产品认证证书

证书编号: CQC2009010305371738

## 申请人名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

## 制造商名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

## 生产企业名称及地址

上海天逸电器有限公司 (V005556)  
上海市松江区车墩镇北闵路 101 号第二、三幢

## 产品名称和系列、规格、型号

### 按钮开关

LA42(A): Ui:400V; Uimp:2.5kV; Ith:10A; AC-15:400V/2.6A, DC-13:220V/0.3A; IP65; 安装孔径:Φ22mm; 型号解释见附件

## 产品标准和技术要求

GB/T14048.5-2017

## 认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 05 月 08 日 有效期至: 2024 年 04 月 04 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任:

陆梅



# 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0258863



# 产品认证证书

附 录

证书编号: CQC2009010305371738

第 1 页 共 2 页

纸 号: 258863

型号解释:

注: 此附录与证书同时使用时有效。

主任: \_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



# 产品认证证书

附录

第 2 页 共 2 页

证书编号: CQC2009010305371738

纸号: 258863

LA42(A) □ □ □ □ □ □

颜色代码: R (红), G (绿), Y (黄), S (蓝), B (黑)  
A (灰), O (橙)

电压: 带灯片电压  
DC/AC220V、110V、48V、36V、24V、12V、  
6V (不带灯产品无此项)

触点: AC01 (缓动一常闭) AC10 (缓动一常开)  
AC11 (缓动一常开一常闭) AC02 (缓动二常闭)  
AC20 (缓动二常开)  
AK01 (速动一常闭) AK10 (速动一常开)  
AK11 (速动一常开一常闭) AK02 (速动二常闭)  
AK20 (速动二常开)

带灯片代号: D (仅适用于平钮) (带灯片型号: AL01)  
空白表示不带灯

钮头代号: 平钮 P 旋钮 X XT (X XT 外形不同)  
(旋钮分两位, 三位制, 在代号后加 2, 3 表示;  
自锁默认表示, 自复位用 A 表示;  
旋转角度自锁 60°默认表示, 自复 45°默认表示,  
自复/自锁旋转角度为 90°在代表示, 自复 45°默认表示,  
自复/自锁旋转角度为 90°在代号后加 9 表示)

型号代码

例: 两位置, 自复位, 旋转角度 90°的蓝色旋钮; 配速动一常开一常闭, 表示为 LA42(A)X2A9-AK11/S

主任:

陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





# PRODUCT CERTIFICATE

**CERTIFICATE NO.: CQC2009010305371738**

**NAME AND ADDRESS OF THE APPLICANT**

Shanghai TAYEE Electric.Co.,Ltd.  
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Shanghai TAYEE Electric.Co.,Ltd.  
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

Shanghai TAYEE Electric.Co.,Ltd. (V005556)  
Building 2&3, No.101, Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

push buttons  
LA42(A): Ui:400V; Uimp:2.5kV; Ith:10A; AC-15:400V/2.6A, DC-13:220V/0.3A; IP65; 安装孔  
径:Φ22mm

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.5-2017

**TYPE OF CERTIFICATION SCHEMES**

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification  
rules of CQC11-462142-2019 .

Valid from: May.08,2020

Valid until: Apr.04,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing  
certification body until the expiry date.

President:

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0258863