



产品认证证书

证书编号: CQC20012241298

申请人名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

上海天逸电器有限公司 (V005556)
上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

按钮开关

LA42(S); Ui:250V; Uimp:4kV; Ith:5A; B300:AC-15:Ue/Ie:120V/3A, 220V/1.8A; P300:DC-13:Ue/Ie:48V/1.1A, 125V/1.1A, 250V/0.55A; R300:DC-13:Ue/Ie:125V/0.22A, 250V/0.1A; AC-12:Ue/Ie:220V/3A, 110V/3A; DC-12:Ue/Ie:48V/3A, 24V/3A; IP40; 安装孔径:Φ16; 型号解释详见附件

产品标准和技术要求

GB/T14048.5-2017

认证模式

产品型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 04 月 07 日 有效期至: 2025 年 04 月 07 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0212075



产品认证证书

附 录

证书编号: CQC20012241298

第 1 页 共 2 页

纸 号: 212075

型号的解释(Explanation of model/ type):

LA42(S) □ □ □ □ - □ - □ / □ - □
1 2 3 4 5 6 7 8 9

1: 型号代码

2: 钮头代号: P(平钮)、PS(自锁平钮)、PD(灯钮)、PSD(自锁灯钮)、M(蘑菇钮)、MS(自锁蘑菇钮)、MD(带灯蘑菇钮)

MSD(自锁带灯蘑菇钮)、J(紧停按钮)、JS(短款紧停按钮)、X(旋钮)、XD(带灯旋钮)、Y(钥匙钮)

3: 位数(适用于钥匙钮、旋钮): 2(2工位)、3(3工位);

4: 自复、自锁型号(适用于钥匙钮、旋钮): 空白(所有工位自锁)、A(所有工位自复)

5: 头部形状: 空白(圆形)、F(方形)

6: 触点: 01(一常闭)、01S(一常闭)、02S(二常闭)、10(一常开)、11(一常开一常闭)、20(二常开) 自由组合;

7: 电压: 带灯片电压(不带灯产品无此项)具体见下表;

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书

附 录

第 2 页 共 2 页

证书编号: CQC20012241298

纸 号: 212075

8: 颜色代码: R (红), G (绿), Y (黄), S (蓝), B (黑), W (白)

带灯片电压 (LED 灯)
AC: 220V、110V、24V、12V、6V
DC: 24V、12V、6V

9: 客户编号:

000-099: ...

100-199: 奥的斯电梯

200-299: 三菱电梯

.

.

.

.

xxx-xxx: ...

注: 此附录与证书同时使用时有效。

主任: _____

陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20012241298

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)
Building 2,3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

button switch

LA42(S); Ui:250V; Uimp:4kV; Ith:5A; B300:AC-15:Ue/Ie:120V/3A, 220V/1.8A; P300:DC-13:Ue/Ie:48V/1.1A,125V/1.1A,250V/0.55A; R300:DC-13:Ue/Ie:125V/0.22A,250V/0.1A; AC-12:Ue/Ie:220V/3A,110V/3A; DC-12:Ue/Ie:48V/3A,24V/3A; IP40; Aperture :Φ16; See the Appendix for type explanation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019 .

Valid from: Apr.07,2020

Valid until: Apr.07,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0212075