



# 产品认证证书

证书编号：CQC2019010307268127

申请人名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

德力西电气（芜湖）有限公司 (V025026)  
安徽省芜湖市芜湖机械工业园

产品名称和系列、规格、型号

剩余电流动作断路器

TYB2LEH;Uimp: 4kV; Ui: 500V; Ue: AC230V(1P+N,2P)、AC400V(3P,3P+N,4P);In: 6A,10A,16A,20A,25A,32A;瞬时脱扣类型: C、D 型;I $\Delta$ n: 30mA,100mA,300mA;额定剩余动作类型: AC 型/电子式;I $\Delta$ m: 630A;Ics: 7.5kA;Icn: 10kA;极数: 1P+N(带 1 个保护极,N 极常通)、2P、3P、3P+N(带 3 个保护极,N 极常通)、4P,1P+N、3P+N 不适用于隔离, 其余适用于隔离

产品标准和技术要求

GB/T16917.1-2014;GB/T16917.22-2008

认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462143-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 07 月 10 日 有效期至: 2024 年 05 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任: 陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0326966



# PRODUCT CERTIFICATE

**CERTIFICATE NO.:** CQC2019010307268127

**NAME AND ADDRESS OF THE APPLICANT**

Shanghai TAYEE Electric.Co.,Ltd.  
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**NAME AND ADDRESS OF THE MANUFACTURER**

Shanghai TAYEE Electric.Co.,Ltd.  
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

**NAME AND ADDRESS OF THE FACTORY**

DELIXI ELECTRIC (WUHU) LTD (V025026)  
Wuhu Machinery Industrial Park, Wuhu City, Anhui Province, 241100, P.R.China

**PRODUCT NAME, MODEL AND SPECIFICATION**

Residual current action breaker

TYB2LEH;Uimp: 4kV; Ui: 500V;Ue: AC230V(1P+N,2P)、AC400V(3P,3P+N,4P);In: 6A,10A,16A,20A,25A,32A;Type C、D;I $\Delta$ n: 30mA,100mA,300mA;AC /Residual Current Trip Unit Electronic ;I $\Delta$ m: 630A; Ics: 7.5kA; Icn: 10kA;Poles: 1P+N(1 protected pole with an uninterrupted neutral pole)、2P、3P、3P+N(Three protected poles with an uninterrupted neutral pole)、4P;Suitable for isolation, except 1P+N、3P+N

**THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T16917.1-2014;GB/T16917.22-2008

**TYPE OF CERTIFICATION SCHEMES**

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: Jul.10,2020

Valid until: May.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: \_\_\_\_\_

Lu Mei



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0326966