



# 产品认证证书

证书编号：CQC2010010301437104

## 申请人名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

## 制造商名称及地址

上海天逸电器有限公司  
上海市松江区车墩镇北闵路 101 号第二、三幢

## 生产企业名称及地址

上海天逸电器有限公司 (V005556)  
上海市松江区车墩镇北闵路 101 号第二、三幢

## 产品名称和系列、规格、型号

低压成套开关设备  
TYZC 主母线:InA=400A~10A,Icw=6kA;Ue=400V、230V,Ui=660V;50Hz;IP55

## 产品标准和技术要求

GB/T7251.12-2013

## 认证模式

型式试验+获证后监督

上述产品符合 CQC11-462176-2018 认证规则的要求，特发此证。  
发证日期：2020 年 08 月 12 日 有效期至：2024 年 12 月 16 日  
证书有效期内本证书的有效性依据发证机构的定期监督获得保持。  
经中国合格评定国家认可委员会认可 CNAS C001-P

主任：陆梅



## 中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0345389



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2010010301437104

## NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.  
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.  
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

## NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)  
No.101 Beimin Road,Chedun Town,Songjiang District,Shanghai,P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies  
TYZC 主母线:InA=400A~10A,Icw=6kA;Ue=400V、230V,Ui=660V;50Hz;IP55

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T7251.12-2013

## TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462176-2018 .

Valid from: Aug.12,2020

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0345389