



产品认证证书

证书编号：CQC2008010301269275

申请人名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

制造商名称及地址

上海天逸电器有限公司
上海市松江区车墩镇北闵路 101 号第二、三幢

生产企业名称及地址

上海天逸电器有限公司 (V005556)
上海市松江区车墩镇北闵路 101 号第二、三幢

产品名称和系列、规格、型号

组合插座箱(配电板)

TYZC InA=250A~10A, Icw=6kA; Ue=400V、230V, Ui=400V; 50Hz; IP65-操作面 IP20C, 户内型

产品标准和技术要求

GB/T7251.3-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462176-2018 认证规则的要求，特发此证。

发证日期：2020 年 08 月 12 日 有效期至：2024 年 10 月 21 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

主任：陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0345387



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2008010301269275

NAME AND ADDRESS OF THE APPLICANT

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shanghai TAYEE Electric.Co.,Ltd.
Building 2&3, No.101 Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shanghai TAYEE Electric.Co.,Ltd. (V005556)
Building 2&3, No.101, Beimin Road, Chedun Town, Songjiang District, Shanghai City, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Distribution Boards
TYZC InA=250A~10A,Icw=6kA;Ue=400V、230V,Ui=400V;50Hz;IP65-操作面 IP20C,户内型

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T7251.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462176-2018 .

Valid from: Aug.12,2020

Valid until: Oct.21,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0345387